

The applicant: **REVESTIMIENTOS Y TECHOS DURALMOND S.L.**  
Región murciana parcela ITC 2/3 P.I. Base 2000  
30564 LORQUI- MURCIA

is authorized to place the label " Certificate of Reaction to Fire of  
Construction Products " according to the report N° 2008AN9182



# aitex

**CERTIFICATE OF REACTION  
TO FIRE OF:**

**CONSTRUCTION PRODUCTS**

**N° 08AN9182**

The reference

**"DURALMOND FORMULA B"**

has been tested in its two sides of use according to the standards UNE  
EN ISO 11925-2:2002 and UNE EN 13823:2002. The classification  
according to standard UNE EN 13501-1:2007 is:


**"C<sub>s2,d0</sub>"**

This certificate has validity until the December 18th 2013

Alcoy, December 19th 2008.



Raquel Muñoz González  
CHIEF OF LABORATORIES AREA



Jordi Ferr Pascual  
HEAD OF FIRE DEPARTMENT

